

# David Mezger Engineering LLC

Tel: Cell 913-481-3774  
Office 816-736-4043

212 NE Circle Dr  
Kansas City, MO 64116

Email:  
mezgerde@gmail.com

**DME**

October 17, 2022


City of Lee's Summit, Building Inspection

Re: Review comments for 4816 NE Freehold Ct.

Dear Sirs,

This is a revision / update to the previous letter addressing Item 6 of the subject review comments which asks for verification of the attachment method for the deck support beam to the house. After discussion with the commenter and review of pictures from the site, it was clear that the beam was not in fact properly fastened to the framing on the house with the correct joist hanger. My recommendation in lieu of replacing the beam with a longer one and cutting the siding back on the house, was to place a new pier supported post near the end of the beam. This has been noted by the designer on the revised issue of the drawings which I have reviewed and re-sealed.

Sincerely,



David E. Mezger P.E.

