

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224073
Address: 4801 NE FREEHOLD CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Tuesday, November 08, 2022

Corrective Action Required:

1	Misc	-Protect plumbing at master bedroom/bathroom bottom wall plate
---	------	--

****OK TO ROCK PENDING CORRECTION OF THE ABOVE DEFICIENCY.**

Comments: