

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20214607

Address: 902 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081904 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081906 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081908 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081910 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081900 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	Michael Harkins	Failed	Wednesday, November 09, 2022

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE ADDRESS  Screw in light pole bases South corner Lowenstein & 900 Between 900 & 914 Between 928 & 932 Between 938 & 1000 Between 1008 & 1012 THE ABOVE HAVE A DRIVEN GROUND ROD BUT STILL REQUIRE BELOW INFORMATION  Provide Documentation for grounding, depth Manufacturers installation instructions Each 4 plex 5 plex has individual permit Call In on correct permits
---	--------------------------	--

Comments:

