## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRRES20216204Address:1932 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	n:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential		Patrick Schonfeldt	Failed	Wednesday, November 09, 2022
Corrective	Action Required:			
1	Misc	-RAISE WATER METER LID TO GRADE, MAINTAIN REQUIRED 14"-18" FROM		
		METER TO LID, CAN BE NO	MORE THAN 18", CURRENT	LY OVER 18"
		TCO HAS EXPIRED, ADDRES EXTENSION LETTER FOR RE	SS ASAP, IF REQUESTING EX EVIEW	TENSION SUBMIT TCO

Comments: