

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220570
Address: 1120 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Michael Harkins	Failed	Wednesday, November 09, 2022

Corrective Action Required:

1	Miscellaneous Correction	LIGHT POLE BASES BLDG # 1 NORTH SIDE TRUCK COURT PROVIDE (8) #6 BARS SPACED EVENLY AROUND REBAR STRUCTURECIRCUMFERENCE WITH #4 TIES WITH 1'-3" MIN LAP AT 12" OC & (3) #4 TIES WITH 1'-3" MIN LAP 3" OC FOR ALL FOUNDATIONS PER CITY APPROVED PLAN
---	--------------------------	--

Comments: