

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201796  
Address: 2309 SW CHASE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Ryan Heckman	Failed	Wednesday, November 09, 2022

Informational:

1 Misc

On 11/22/2021 I performed a sidewalk inspection and pass the subgrade to pour concrete

11-9-22 RH. Two panels were cracked and will need replaced before passing.

**Comments:**