



**LEE'S SUMMIT**  
MISSOURI



---

## FIRE DEPARTMENT

Prevention Division  
(816)969-1300

### PLAN REVIEW CONDITIONS

November 10, 2022

3F30 ARCHITECTS  
7501 NW TIFFANY SPRINGS PARKWAY STE 240  
KANSAS CITY, MO 64153

Permit No: PRCOM20225390  
Project Title: MAMON LLC  
Project Address: 3540 SW MARKET ST, LEES SUMMIT, MO 64082  
Parcel Number: 70500031400000000  
Location: SUMMITCREST PLAZA LOT 1--- LOT 1  
Type of Work: CHANGE OF TENANT  
Occupancy Group: MERCANTILE  
Description: TENANT FINISH FOR SALE OF TOBACCO PRODUCTS

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

#### **Building Plan Review**

**Reviewed By: Joe Frogge**

**Rejected**

1. A code analysis shall be provided which includes but is not limited to occupancy type, occupant load, construction type, actual area, height and floors, allowable area, height and floors, and the codes to which the project is designed.

Action required: Provide complete code analysis. (fyi - this building is a fully sprinklered VB)

2. 2018 IBC 2902.3 Employee and public toilet facilities. For structures and tenant spaces intended for public utilization, customers, patrons and visitors shall be provided with public toilet facilities. Employees associated with structures and tenant spaces shall be provided with toilet facilities. The number of plumbing fixtures located within the required toilet facilities shall be provided in accordance with Section 2902 for all users. Employee toilet facilities shall be either separate or combined employee and public toilet facilities.

Exception: Public toilet facilities shall not be required for:

1. Parking garages where operated without parking attendants.
2. Structures and tenant spaces intended for quick transactions, including takeout, pickup and drop-off, having a public access area less than or equal to 300 square feet.

Action required: Comment is for informational purposes. Public access to restroom will be required.

3. Smoking inside commercial facilities is prohibited by ordinance Sec. 17-305.

Action required: Comment is informational.

#### **Fire Plan Review**

**Reviewed By: Ben Hicks**

**Rejected**

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Action Required: Any changes to alarm system send shop drawings to Lee's Summit Fire for approval

2. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Action Required: Any changes to fire protection system send approved shop drawings to Lee's Summit Fire for approval.

3. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action Required: Any changes to systems call 816-969-1300 to schedule acceptance testing.

4. Complete code analysis to include occupant load.

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***