

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20220466  
Address: 196 SW WINTER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Thursday, November 10, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- Install fire place deck-secure ward flex</li><li>- Provide joist hangers on.LVLS above double non load bearing wall-Use proper hangers</li><li>- Address both hip rafters over notched In master bedroom-Complete per engineer's letter and remove insulation for inspection</li><li>- Support ridge north charlottes room-Support hip rafters at same location</li><li>- Fire block fur out wall west side And check all fur downs-fire block fur down at fur out wall west bed</li></ul> <p><b>**OK TO INSULATE-DO NOT COVER INSPECTION ITEMS</b></p>
---	------	---

**Comments:**