

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215418
Address: 1536 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, November 10, 2022

Corrective Action Required:

1	Misc	-resolve outstanding inspection fees -remove old silt fence, construction debris and trash at rear of lot -provide handrail at rear patio stairs -provide gravel base at water meter -cap and label future vent at basement -provide AFCI protection at kitchen circuits -AC max overcurrent protection listed 30 amps
---	------	--

Comments: