

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212842  
Address: 1900 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Thursday, November 10, 2022

Corrective Action Required:

1	Misc	-resolve outstanding inspection fees -splash blocks -provide gravel base at water meter -cover plates at laundry outlets, master bath -no access to jacuzzi tub motor master bedroom with current configuration, motor on opposite end of tub IRC P2720.1 -mark dedicated outlets at unfinished spaces as not GFCI protected -provide water pressure regulator at main water line
---	------	---

Comments: