

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222754
Address: 2217 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Thursday, November 10, 2022

Corrective Action Required:

1	Miscellaneous Correction	No deck pier inspection on covered deck CS-PF per IRC R602.10 Provide CS-PF exterior bracing at foyer per plan (header to jack stud straps per table R602.10.6.4 NOT DONE) Provide CS-PF window left of fireplace (provide straps) NOT DONE Provide CS-PF nailing 3 windows great room NOT DONE Provide electrical nail guard at bed 3 vanity Basement (NOT DONE 10/11/22) Marked with red ink pen again
---	--------------------------	--

Comments: