

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20222496

Address: 2501 NE COLBERN RD, LEES SUMMIT, MO 640862601 NE COLBERN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Detention Basin</b>	Adam Nacke	Failed	Thursday, November 10, 2022

Corrective Action Required:

1	Miscellaneous Correction	11-10-22 AN 1 of the basin appears to be completed but since we ran out of time for vegetation, skimmers need to be installed on both basins
---	--------------------------	--

**Comments:**