

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214577  
Address: 3116 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:       | Outcome: | Date:                       |
|-------------------------------------------------|------------------|----------|-----------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Mitchell Schwarz | Failed   | Thursday, November 10, 2022 |

Corrective Action Required:

|   |      |                                                                                                                                                                                                                                                            |
|---|------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -clean mud and dirt from driveway and sidewalk<br>-pay all fees<br>-provide code compliant access for Jacuzzi tub motor in master<br>-cover plate for outlet in master toilet room<br>-splash blocks and sump pump discharge to extend 36" from foundation |
|---|------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**