

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220897

Address: 1002 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811004 NW BLACK TWIG CIR, LEES SUMMIT,
MO 640811006 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811008 NW BLACK TWIG
CIR, LEES SUMMIT, MO 640811000 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Thursday, November 10, 2022

Corrective Action Required:

1	Miscellaneous Correction	1000 Nail joist hanger under landing Fire blocking master closet
		1002 Nail joist hangers garage Seal fire block behind pre rock closet behind laundry
		1004 Screw clip rear corner garage Fire block behind pre rock closet behind
		1006 OK
		1008 Ok

Comments: