

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20222819  
Address: 2113 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Friday, November 11, 2022

Corrective Action Required:

1	Miscellaneous Correction	No deck pier inspection on record Nail exterior wall sheathing CS-PF at SGD per code-RIM JOIST Tighten anchor bolts basement Nail wall corners together at family room bed 3-EXTERIOR WALLS REQUIRE (3) STUDS NAILED PER CODE **OK TO INSULATE-DO NOT COVER INSPECTION ITEMS
---	--------------------------	--

Comments: