

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215295
Address: 2110 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, November 11, 2022

Corrective Action Required:

1	Misc	inspection denied -no address posted. -erosion control not in compliance -address rafter to ceiling joist connection -address rafter/ceiling joist to top plate connection to be to plans -address s3.2 10 connections at deck -complete bath vent fans install though out -address RA panning at Rex room to unfinished area -complete concrete room electrical
---	------	--

Comments: