

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220226  
Address: 4871 SW RAINTREE PKWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Friday, November 11, 2022

Corrective Action Required:

1	Misc	-complete framing for dumbwaiter with truss flooring modifications complete, have mitek engineer letter in site at reinspection, upload engineer letter to portal, seal electrical penetration at plate and secure electrical wire
---	------	--

**\*\*OK TO INSULATE\*\***

**Comments:**