

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223253
Address: 1063 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, November 11, 2022

Corrective Action Required:

1	Misc	-Install all windows -Protect wire at entry into fireplace -Fill in voids at basement walkout door strike plate side and hinges per security code; provide security blocking -Seal return air space above rear basement bedroom closet -Parallel electrical within rear basement bedroom wall return air space -Fb dead space adjacent to basement bathroom from joist and soffit space
---	------	--

****OK TO INSULATE**

Comments: