

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20224010  
Address: 3509 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Patrick Schonfeldt	Failed	Friday, November 11, 2022

Corrective Action Required:

1	Misc	PROVIDE PROTECTION PLATES AT DWV TOP PLATE, SILL PLATE, STUD PENETRATIONS 1 1/4" OR LESS FROM END OF PLATE/STUD - 110,111,113,112,115,119,122,127,128,103, 128,101, DO NOT COVER WITH ROCK ROOMS WITH PLUMBING UNTIL REINSPECTION
---	------	---

Informational:

2	Misc	ROOMS APPROVED FOR COVER 109,105,106,108, 102,125, 124,123,121,107,126
---	------	--

**Comments:**