

Architect's Supplemental Instructions Narrative

Project	LSR7 Robotics, GiC and Physical Education - LSW	ASI Number	One (001)
Project No	0121-0100	Issue Date	November 11, 2022
Owner	Lee's Summit R-7 School 301 Tudor Road Lee's Summit, MO 64086	Contract Date	
Architect	Multistudio 706 Massachusetts St Lawrence, KS 66044	Contractor	Newkirk Novak 11200 W 79 th St Lenexa, KS 66214

To All Bidders:

This Architect's Supplemental Instructions forms a part of the Contract Documents and modifies the original Bidding Documents dated: September 9, 2022, and all subsequent addenda. Receipt of this Architect's Supplemental Instructions must be acknowledged in the space provided in the Bid Form.

1. Changes to Specifications

- A. Section 077200 – ROOF ACCESSORIES
 - i. Remove section in it's entirety and replace with revised specification.
 - 1. Added sub-section 2.3, F Non-Penetrating Fall Protection.

2. Changes to Civil Drawings

- A. C000-A General Layout Sheet
 - i. Added sheet to document set.
- B. C101-A LSW Site and Dimension Plan
 - i. Revised zoning.
 - ii. Added classroom and parking counts.
 - iii. Added site setback requirements.

3. Changes to Architectural Drawings

- A. A201 – Exterior Elevations
 - i. Details A3, F3, L3 and L11: Added color finish of exterior elements.
 - ii. Detail A3: Added Knox Box.

- B. A322 – Exterior Section Details
 - i. Added roof hatch guardrail extensions.

4. Changes to Electrical Drawings

- A. E700 – LIGHTING SCHEDULES
 - i. Added notation regarding egress lighting controls.

End of Narrative