

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20214053
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Punch List Inspection	Ryan Heckman	Partial	Monday, November 14, 2022

Informational:

1 Misc

10-26-22 RH.

1. All areas with a Dot can be grouted.
2. All areas with an X need replaced from joint to joint.
3. All cables on Storm inlets need to be removed and grouted.
4. All storm lids need be lifted and made sure they are grouted on inside.

11-4-22 RH. Redford has started working on punch list items around the subdivision.

11-14-22 RH. No work being done on site today.

Comments: