

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213908
Address: 2317 SW CHASE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, November 14, 2022

Corrective Action Required:

1	Misc	-address pending footing inspection -address pier inspection not passed -obtain lawn irrigation permit -gutters to be installed -cap off open dwv in garage -anti syphon device at water in basement -address siding from grade at rear of home multiple areas -tamper caps at A/c unit
---	------	--

Comments: