

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20224162
Address: 3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|---------------------------|
| Erosion Sediment Control (ESC) Inspection | Eric Sharp | Partial | Monday, November 14, 2022 |

Informational:

| | | |
|---|------|---|
| 1 | Misc | Erosion control measures installed mostly on the pergola park 5th plat areas. 9/6/22 ES |
| | | Erosion control measures installed on 5 plat areas below this permit are intact and functioning. 9/12/22. ES |
| | | Erosion control installed, intact and functioning. 9/26/22 ES |
| | | Erosion control measures installed, intact, and functioning. 10/3/22 ES |
| | | Erosion control measures installed, intact, and functioning. 10/10/22 ES |
| | | Erosion control measures installed, intact and functioning. 10/18/22 ES |
| | | Rain event 10/24, erosion control measures functioning, mostly installed on neighboring plats. 10/25/22 ES |
| | | Erosion control measures installed, intact, and functioning. 10/31/22 ES |
| | | Erosion control measures installed, intact, and functioning. Measures held up to rain even from 11/4, had conversation with crews about keeping mud off |

of existing roads. 11/7/22 ES

Erosion control measures installed, intact, and functioning. With snow coming tonight/tomorrow did readdress issues with mud on roadways.
11/14/22 ES

Comments: