



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20110115, Building Permit - Commercial  
Address: 970 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	John Borns	Partial	Friday, April 29, 2011

Partial Correction			
1 MISC		SUPPORTS OF ROOFTOP PIPING IN PROGRESS	

<b>Gas Service Inspection - Commercial</b>	John Borns	Failed	Friday, April 29, 2011
--	------------	--------	------------------------

Corrective Action Required			
1 MISC		GAS PIPING PRESSURE TEST DECREASED DURING MONITORING PERIOD	

**Comments:**