

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216110
Address: 3528 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Patrick Schonfeldt	Failed	Tuesday, November 15, 2022

Corrective Action Required:

1	Misc	-PROVIDE PLUMBING PROTECTION AT BATHROOMS -PROVIDE ADA COMPLIANT BATHROOM SIGNS -GFCI PROTECTION ALL KITCHEN OUTLETS -ANTI SIPHON DEVICE AT MOP SINK SPIGOT -SECURE MC AT SERVICE PANEL MECH ROOM -PROVIDE DOCUMENTATION ON BACKFLOW CERT AT SOFT DRINK FOUNTAIN, DEVICE ASTM 1022 COMPLIANT
---	------	--

Comments: