

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20203605

Address: 500 NW OLIVE ST, LEES SUMMIT, MO 64063412 NW OLIVE ST, LEES SUMMIT, MO 64063408 NW  
OLIVE ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	John Jackson	Partial	Wednesday, November 16, 2022

Informational:

1 Misc

11/16/22 Wednesday JMJ ( Howerton Plumbing )

Taking sample from end of line. Contractor had to retake sample because a water valve to project was discovered closed when should have been open. Water line was thoroughly flushed before first sample was taken.

**Comments:**