

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20222496

Address: 2501 NE COLBERN RD, LEES SUMMIT, MO 640862601 NE COLBERN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Air Test</b>	Adam Nacke	Partial	Wednesday, November 16, 2022

Informational:

1 Misc

11-3-22 AN. Hydrostatic test for low pressure sewer main at 80 psi for 2hours  
Line 1, 2 and part of 3 up to Blackwell passed

On line 3 we still need to hydrostatic test all the main that is getting bored  
off of Blackwell

11-16-22 AN Redford started the hydro tested the line 3 Blackwell and  
neighborhood line at 9:25. 80psi

**Comments:**