

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214609

Address: 934 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081936 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081938 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081932 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Wednesday, November 16, 2022

Corrective Action Required:

2	Miscellaneous Correction	932 Ok
---	--------------------------	--------

934
Fire block HVAC chase bed closet

936 Ok

938
Vertical Fire block every 10' garage
Seal fire block garage
Land conductors in a box or listed fixture garage/porch
Nail hold down under living room window

Comments: