

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215028

Address: 2603 NE MCBAINE DR, LEES SUMMIT, MO 640642605 NE MCBAINE DR, LEES SUMMIT, MO
640642607 NE MCBAINE DR, LEES SUMMIT, MO 640642609 NE MCBAINE DR, LEES
SUMMIT, MO 640642611 NE MCBAINE DR, LEES SUMMIT, MO 640642613 NE MCBAINE
DR, LEES SUMMIT, MO 640642615 NE MCBAINE DR, LEES SUMMIT, MO 640642617 NE
MCBAINE DR, LEES SUMMIT, MO 640642601 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|------------|----------|---------------------------------|
| Sidewalk Inspection | Adam Nacke | Passed | Wednesday, November 16, 2022 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | 10-26-22 AN busted sidewalk panel needs to be fixed. Contractor knows about the panel and said he will get it fixed 11-16-22 AN sidewalk has been replaced |
|---|------|---|

Comments: