

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20215295
Address: 2110 SW RED BARN LN, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed - Stop Work	Wednesday, November 16, 2022

Corrective Action Required
1 Misc

UNCOVER ALL ITEMS IN NEED OF INSPECTION

- address rafter to ceiling joist connection
- address rafter/ceiling joist to top plate connection to be to plans
- address s3.2 10 connections at deck
- complete bath vent fans install though out
- address RA panning at Rec room to unfinished area
- complete concrete room electrical

Comments: