CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213548 Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Wednesday, November 16, 2022
Corrective Action Required: 1 THIRD FLOOR	AREA "A" UNITS AND CORRIDOR APPROVED		
Corrective Action Required: 2 SECOND FLOOR	AREA "B" UNITS AND CORRIDOR AP	PROVED	
	AREA "C" UNITS AND CORRIDOR API	PROVED	
	AREA D UNITS AND CORRIDOR AP	PROVED	
	AREA A UNITS AND CORRIDOR API	PROVED	
	AREA B UNITS AND CORRIDOR AP	PROVED	
	AREA C UNITS AND CORRIDOR AP	PROVED	

Corrective Action Required: 3 FIRST FLOOR	AREA D UNITS AND CORRIDOR APPROVED	
	AREA A UNITS AND CORRIDOR APPROVED	
		AREA B -COMMON AREAS INCOMPLETE
		AREA C UNITS AND CORRIDOR APPROVED
		AREA D UNITS AND CORRIDOR APPROVED EXCEPT AS NOTED: 102-NOT READY
Corrective Action Required:		
4	ELEVATOR 1	
Corrective Action Required:		
5	STAIR TOWER 1	-PROVIDE VERTICAL FIREBLOCKING MAX 10' OC AT SHARED WALL
	Action Required:	
6 Corroctivo	STAIR TOWER 2	PROVIDE VERTICAL FIREBLOCKING
7	Action Required:	SEAL GAPS AT FIREBLOCKING
•	Action Required:	
8	STAIR TOWER 4	SEAL GAPS AT FIREBLOCKING

Comments: