



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110385, Building Permit - Commercial
Address: 3390 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	David Landes	Failed	Friday, April 29, 2011

Corrective Action Required

1	MISC	- SUB-PANEL NOT LABELED & BREAKERS NOT LABELED
---	------	--

Rough Plumbing Inspection - Commercial	Mark Harding	Passed	Friday, April 29, 2011
---	--------------	--------	------------------------

Comments: