



October 31, 2022

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

**RE: Field Issue of deck beam support for Lot #125 Manor at Stoney Creek – 1920 SW Merryman Dr.
Lee's Summit, MO 64082 – Permit # PRRES20214879**


- Inspector Comment #1: Provide approved hanger at triple and double deck beam to ledger connection at deck.

Findings:

- Approved hanger not installed at deck beam connection to corner of house.
- Approved hanger not installed at double joist at deck end joist.

Recommended modifications:

- Install full height 6x6 cedar post on Simpson ABU66 post base with "J" and "G" size footing as shown in image below:



Sincerely,

Bradley Huxol, PE

