

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20203605

Address: 500 NW OLIVE ST, LEES SUMMIT, MO 64063412 NW OLIVE ST, LEES SUMMIT, MO 64063408 NW
OLIVE ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 2	John Jackson	Partial	Thursday, November 17, 2022

Informational:

1 Misc

11/17/22 Wednesday JMJ (Howerton Plumbing)
Collected the second required water sample. After two consecutive passing samples water valve can remain open and installed water lines for project can be part of the Lee's Summit public water system.

Comments: