

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216304
Address: 3201 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, November 17, 2022

Corrective Action Required:

1	Misc	-provide as graded plot plan -pay all fees -obtain issued lawn irrigation permit -garage GFCI outlet closet to stairs in garage not working properly -spark ring as required by code for kitchen outlets where greater than 3/8 gap -spark ring for outlet above fire place -stairs greater than 3/8 difference in rise at back patio -GFCI outlet for disposal in kitchen
---	------	---

Comments: