

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215208  
Address: 209 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Thursday, November 17, 2022

Corrective Action Required:

1	Miscellaneous Correction	Seal upward penetration above kitchen hood Fire block dropped ceiling line powder room Address 1 1/2 bearing of LVL near service panel garage Address rafters landing on multiple plates throughout Seal fire blocking in dead space rec area Seal garage steps at foundation wall Fire joist space bed 3 closet Secure return air grill bed 3
---	--------------------------	---

Comments: