

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20214609

Address: 934 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081936 NW BLACK TWIG CIR, LEES SUMMIT, MO  
64081938 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081932 NW BLACK TWIG CIR, LEES  
SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Failed	Thursday, November 17, 2022

Corrective Action Required:

1	Miscellaneous	932 Ok
	Correction	934 Ok
		936 Ok

938

Vertical Fire block every 10' garage-NOT DONE

Seal fire block garage-SEAL GAPS IN VERTICAL AND COMPLETE VERTICAL FB

Nail hold down under living room window-NOT DONE

**Comments:**