

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215281

Address: 3651 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643651 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643651 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643651 NE AKIN DR, Unit:E, LEES
SUMMIT, MO 640643651 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	Khanh Nguyen	Failed	Thursday, November 17, 2022

Corrective Action Required:

1	Misc	-Gas test fails for units B and E
---	------	-----------------------------------

Comments: