

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220590
Address: 520 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Thursday, November 17, 2022

Corrective Action Required:		
1	Miscellaneous Correction	PROVIDE ANCHOR BOLTS NUTS & WASHERS AT HOLDDOWNS IN COOLER AREA COMPLETE MEPs FOR IN WALL INSPECTION

Comments: