

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214879  
Address: 1920 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Not Ready	Thursday, November 17, 2022

Corrective Action Required:

1	Misc	11/17/22 -NO ACCESS DOORS, NO LOCKBOX CODE PROVIDED -pay fees -2nd floor stairs, basement stairs 34"-38" height handrail IRC R311.7.8.1 -(2) 1/2" through bolts each post/beam connection at deck
---	------	--

**Comments:**