



September 20, 2022

Walker Custom Homes
Attn: Ryan Hamilton

Re: Inspection Letter: RHF059 Spec Lot 59 The Retreat at Hook Farms 1st Plat – 2118 SW Red Barn Ln., Lee’s Summit, Missouri

Vista Structural Engineering, LLC was asked to address the following rough-in inspection items for the project located at above referenced address. Please see the following responses w/ attached documentation, and site photos for reference.

- 1) **Inspection comment:** “Address deck post to beam connection. See attached pictures of the 3 post to beam connections.”


Vista Structural’s response: *We recommend adding two LCE4 post caps at the outer face of the two corner posts and two AC6 post caps at the outer face of the interior post. A sketch has been attached on the following page for clarification, and pictures on the following pages.*

Our firm appreciates the opportunity to serve you. If you have any questions or if you need anything further, please feel free to contact us.

Sincerely,

Vista Structural Engineering, LLC

Dennis Heier, P.E.






Figure 1 – Installation locations of post caps




Figure 2 – Corner Posts




Figure 3 – Middle post