



November 17, 2022

Walker Custom Homes, LLC  
Attn: Jason Walker

Re: 2110 SW Red Barn Lane, Lee's Summit, MO (Permit # PRRES20215295)

Vista Structural Engineering, LLC, was asked to address the following city inspection comment for the house being built at 2110 SW Red Barn Lane, in Lee's Summit, MO:

- **Address rafters landing on blocks throughout.** *We recommend fastening the rafters and ceiling joists as shown on detail 7/S3.2. This detail is on the approved plans, and has also been attached to the following page for convenience. We asked for a random spot verification of this connection, for which a picture has been included on page 3 of this report. The connection shows three face nails from the ceiling joist to the rafter and three toenails from the ceiling joist to the plate. We recommend approval of this connection as currently framed.*

Our firm appreciates the opportunity to serve you. If you have any questions or if you need anything further, please feel free to contact us.

Sincerely,  
Vista Structural Engineering, LLC


Dennis Heier, P.E.




# VISTA STRUCTURAL ENGINEERING, LLC

14718 NW DELIA STREET  
PORTLAND, OREGON 97229

PHONE: 971.233.6099  
VISTASTRUCTURAL.COM



**7** RAFTER BEARING OPTION DETAIL  
**S3.2** SCALE: 1" = 1'-0" (18x24) OR 1/2" = 1'-0" (24x36)



# VISTA STRUCTURAL ENGINEERING, LLC

14718 NW DELIA STREET  
PORTLAND, OREGON 97229

PHONE: 971.233.6099  
VISTASTRUCTURAL.COM



# VISTA STRUCTURAL ENGINEERING, LLC

14718 NW DELIA STREET  
PORTLAND, OREGON 97229

PHONE: 971.233.6099  
VISTASTRUCTURAL.COM