



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20110115, Building Permit - Commercial  
Address: 970 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	John Borns	Partial	Friday, April 29, 2011
Partial Correction			
1 MISC		SUPPORTS OF ROOFTOP PIPING IN PROGRESS	
Corrective Action Required			
2 MISC		EXPOSED PIPING TO BE PAINTED BEFORE FINAL INSPECTION	
<b>Gas Service Inspection - Commercial</b>	John Borns	Passed	Friday, April 29, 2011
<b>Gas Piping Inspection - Commercial</b>	John Borns	Partial	Friday, April 29, 2011
Partial Correction			
1 MISC		SUPPORTS OF ROOFTOP PIPING IN PROGRESS	
<b>Gas Service Inspection - Commercial</b>	John Borns	Failed	Friday, April 29, 2011

Corrective Action Required  
1 MISC

GAS PIPING PRESSURE TEST DECREASED DURING  
MONITORING PERIOD

**Comments:**