

## CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

## **Inspection Summary**

Permit #: PRCOM20110360, Building Permit - Commercial

Address: 970 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Rated Assembly John Borns Partial Friday, April 29, 2011

Inspection

Partial Correction

1 MISC

Partial Correction 2 MISC

TOP OF TYPE [1] WALL NOT CONSTRUCTED PER DETAIL 6/A101.

PVC ROOF DRAIN PIPING PENETRATES TYPE [1] WALL AT EAST END OF CORRIDOR. CONSULT A/E FOR DIRECTION COMPLIANT

WITH UL-LISTED PENETRATION DESIGN. A/E MUST ISSUE

WRITTEN DIRECTION.

Comments: