

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20214153

Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081
2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Eric Sharp	Passed	Friday, November 18, 2022

Informational:

1 Misc

Tyler, Rudy and crew installed 4 - 2" service meters. 2 for each apartment complex. Then ran those 2 in lines into a 4" C900 line to run into building using all copper line and brass fittings from main to 4" Tee with reducers installed. 5/5/22 ES

Rudy's crew removed 1" irrigation meter and assembly from Lot 7A area, and installed 2 new 1.5" irrigation taps on west side of apartments for apartments and villas. 5/20/22 ES

Water services have been installed. 11/18/22 ES

Comments: