

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20210263

Address: 1801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW HOPE LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Partial	Friday, November 18, 2022

Corrective Action Required:

2	SECOND FLOOR	AREA "A" Complete
---	--------------	----------------------

Corrective Action Required:

3	THIRD FLOOR	Complete
---	-------------	----------

Corrective Action Required:

4	FOURTH FLOOR	AREA "A" complete
---	--------------	----------------------

Area B

4017-missing cover plate at fire wall, remove putty packs

Corrective Action Required:

5	FIFTH FLOOR	AREA "A" complete
---	-------------	-------------------

Area B

5017-seal penetrations at elevator in lobby

**Comments:**