

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216411
Address: 710 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water - Material Verification	Eric Sharp	Passed	Friday, November 18, 2022

Informational:

1 Misc

They had an 8x8x6" fusion epoxy coated tee, 6" gate valve, and epoxy coated fittings for their water tie in and connection to backflow vault. Had 6" C900 PVC pipe for fire line and a ductile stand pipe for riser coming into building. Also had a Kennedy hydrant with epoxy coated shoe delivered for the end of their fire line. Used poly for their domestic and irrigation lines after copper from main and 10' out back side of meter pit. 11/18/22 ES

Comments: