

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20216411  
Address: 710 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 2</b>	Eric Sharp	Passed	Friday, November 18, 2022

Informational:

1 Misc

2nd set of samples taken and delivered to Keystone labs. 6/23/22 ES

2nd set had a fail on sample #2. 6/24/22 ES

2nd set of samples pulled in am of 6/29 and delivered to Keystone labs.  
6/29/22 ES

There were failures on this line beyond the backflow due to contractor pulling from fire hydrant. Spoke with WU and the line is considered passed as we had 4 samples with passes at the public side of backflow vault.  
11/18/22 ES

**Comments:**