

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215028

Address: 2603 NE MCBAIN DR, LEES SUMMIT, MO 640642605 NE MCBAIN DR, LEES SUMMIT, MO  
640642607 NE MCBAIN DR, LEES SUMMIT, MO 640642609 NE MCBAIN DR, LEES  
SUMMIT, MO 640642611 NE MCBAIN DR, LEES SUMMIT, MO 640642613 NE MCBAIN  
DR, LEES SUMMIT, MO 640642615 NE MCBAIN DR, LEES SUMMIT, MO 640642617 NE  
MCBAIN DR, LEES SUMMIT, MO 640642601 NE MCBAIN DR, LEES SUMMIT, MO  
64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Water Utilities</b>	Joe San Nicolas	Passed	Wednesday, November 09, 2022

Corrective Action Required:

1	Misc	Eric Wiggins advised Chris that we need the backflow reports for fireline and fireline bypass. Chris said he would get those submitted.
---	------	---

**Comments:**