

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211543  
Address: 1905 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Friday, November 18, 2022

Corrective Action Required:

1	Misc	-Obtain lawn irrigation permit and submit backflow valve test report to city. Permit application is still in incomplete status
		-Water meter and sewer manhole at NW corner of lot are buried
		-Provide address on contrasting background
		-Provide sewer tracer wire port at grade

**Comments:**